




Residential Energy Submittal Information







1



2



3



4

Definitions

BUILDING THERMAL ENVELOPE

The basement walls, exterior walls, floors, ceiling, roofs and any other building element assemblies that enclose conditioned space or provide a boundary between conditioned space and exempt or unconditioned space



© 2024 Shums Coda Associates

5

5

Definitions

FENESTRATION. Products classified as either vertical fenestration or skylights.

Skylights

Glass or other transparent or translucent glazing material installed at a slope of less than 60 degrees from horizontal including unit skylights, tubular daylighting devices, and glazing materials in solariums, sunrooms, roofs and sloped walls.

Vertical fenestration

Windows that are fixed or operable, opaque doors, glazed doors, glazed block and combination opaque/glazed doors composed of glass or other transparent or translucent glazing materials and installed at a slope of not less than 60 degrees from horizontal.



© 2024 Shums Coda Associates


6

6

Definitions

HIGH-EFFICACY LIGHT SOURCES

Any lamp with an efficacy of not less than 65 lumens per watt, or luminaires with an efficacy of not less than 45 lumens per watt.



© 2024 Shums Coda Associates

7

7

Definitions

DWELLING UNIT ENCLOSURE AREA

The sum of the area of ceiling, floors, and walls separating a dwelling unit's conditioned space from the exterior or from adjacent conditioned or unconditioned spaces. Wall height shall be measured from the finished floor of the dwelling unit to the underside of the floor above.



© 2024 Shums Coda Associates

8

8

Definitions

CAVITY INSULATION
 Insulating material located between framing members



© 2024 Shums Coda Associates

9

9

Definitions

CONTINUOUS INSULATION (ci)

Insulating material that is continuous across all structural members without thermal bridges other than fasteners and service openings. It is installed on the interior or exterior, or is integral to any opaque surface, of the building envelope.



© 2024 Shums Coda Associates

10

10

Definitions

SUNROOM
 A one-story structure attached to a dwelling with a glazing area in excess of 40 percent of the gross area of the structure's exterior walls and roof.



© 2024 Shums Coda Associates

11

11

Definitions

RESIDENTIAL BUILDING

For this code, includes detached one- and two-family dwellings and townhouses as well as Group R-2, R-3 and R-4 buildings three stories or less in height above grade plane.



© 2024 Shums Coda Associates


12

12

R103.2 Information on construction documents

Construction documents shall be drawn to scale on suitable material. Electronic media documents are permitted to be submitted where approved by the code official. Construction documents shall be of sufficient clarity to indicate the location, nature and extent of the work proposed, and show in sufficient detail pertinent data and features of the building, systems and equipment as herein governed. Details shall include the following as applicable:

1. Energy compliance path.
2. Insulation materials and their R-values.
3. Fenestration U-factors and solar heat gain coefficients (SHGC).
4. Area-weighted U-factor and solar heat gain coefficients (SHGC) calculations.
5. Mechanical system design criteria.
6. Mechanical and service water-heating systems and equipment types, sizes and efficiencies.
7. Equipment and system controls.
8. Duct sealing, duct and pipe insulation and location.
9. Air sealing details



© 2024 Shums Coda Associates 13


13

1. Energy compliance path

CODE ENFORCEMENT:

- 2021 INTERNATIONAL BUILDING CODE
- 2021 INTERNATIONAL ENERGY CONSERVATION CODE
- 2021 INTERNATIONAL EXISTING BUILDING CODE
- 2021 INTERNATIONAL FUEL GAS CODE
- 2021 INTERNATIONAL MECHANICAL CODE
- 2021 INTERNATIONAL PLUMBING CODE
- 2021 INTERNATIONAL RESIDENTIAL CODE
- 2021 NATIONAL GREEN BUILDING STANDARDS
- 2023 NATIONAL ELECTRICAL CODE

ENERGY COMPLIANCE: PRESCRIPTIVE PATH



© 2024 Shums Coda Associates 14

14

R401.2.1 Prescriptive Compliance Option

The Prescriptive Compliance Option requires compliance with Sections R401 through R404.

R402.1.2 Insulation and fenestration criteria

(U-factor table)

R402.1.3 R-value alternative (R-value table)

R402.1.4 R-value computation

R402.1.5 Total UA alternative (REScheck)

R402.1.3 R-value alternative (R-value table)

Insulation: Provide a Fully Insulated Building Thermal Envelope As Follows:

FENESTRATION U-FACTOR ^{1a}	SKYLIGHT U-FACTOR ²	GLAZED FENESTRATION SHGC ^{3a}	CEILING R-VALUE	WOOD FRAME WALL R-VALUE ⁴	MASS WALL R-VALUE ⁵	FLOOR R-VALUE	BASEMENT WALL R-VALUE ^{6a}	SLAB R-VALUE AND DEPTH ^{7a}	CRAWL SPACE WALL R-VALUE ⁸
0.30	0.55	40	60	10R OR 20+5 OR 13+10ci	13/17	30	15ci OR 19 OR 13+5ci	10ci, 4 FT.	15ci OR 19 OR 13+5ci

For SI: 1 foot = 304.8 mm.
NR = Not Required.

a. R-values are minimums. U-factors and SHGC are maximums. Where insulation is installed in a cavity that is less than the label or design thickness of the insulation, the installed R-value of the insulation shall be not less than the R-value specified in the table.

b. The fenestration U-factor column excludes skylights. The SHGC column applies to all glazed fenestration.

c. Exception: In Climate Zones 0 through 3, skylights shall be permitted to be excluded from glazed fenestration SHGC requirements provided that the SHGC for such skylights does not exceed 0.30.

d. "5ci or 13" means R-5 continuous insulation (ci) on the interior or exterior surface of the wall or R-13 cavity insulation on the interior side of the wall. "10ci or 13" means R-10 continuous insulation (ci) on the interior or exterior surface of the wall or R-13 cavity insulation on the interior side of the wall. "15ci OR 19 OR 13 + 5ci" means R-15 continuous insulation (ci) on the interior or exterior surface of the wall or R-19 cavity insulation on the interior side of the wall, or R-13 cavity insulation on the interior of the wall in addition to R-5 continuous insulation on the interior or exterior surface of the wall.

e. R-5 insulation shall be provided under the full slab area of a heated slab in addition to the required slab edge insulation R-value for slabs, as indicated in the table. The slab-edge insulation for heated slabs shall not be required to extend below the slab.

f. There are no SHGC requirements in the Marine Zone.


g. Basement wall insulation shall not be required in Warm Humid locations as defined by Figure N1101.7 and Table N1101.7.

h. The first value is cavity insulation; the second value is continuous insulation. Therefore, as an example, "13 + 5" means R-13 cavity insulation plus R-5 continuous insulation.

i. Mass walls shall be in accordance with Section N1102.2.5. The second R-value applies where more than half of the insulation is on the interior of the mass wall.

j. A maximum U-factor of 0.32 shall apply in Climate Zones 3 through 8 to vertical fenestration products installed in buildings located either:

1. Above 4,000 feet in elevation, or
2. In windborne debris regions where protection of openings is required by Section R301.2.1.2.



© 2024 Shums Coda Associates 15

15

R402.1.5 Total UA alternative (REScheck)


Compliance: Passes using UA trade-off

Compliance: **0.0% Better Than Code** Maximum UA: **270** Your UA: **270**
 The % Better or Worse Than Code index reflects how close to compliance the house is based on code trade-off rules.
 It DOES NOT provide an estimate of energy use or cost relative to a minimum-code home.

Slab-on-grade tradeoffs are no longer considered in the UA or performance compliance path in REScheck. Each slab-on-grade assembly in the specified climate zone must meet the minimum energy code insulation R-value and depth requirements.

Envelope Assemblies

Assembly	Gross Area or Perimeter	Cavity R-Value	Cont. R-Value	Prop. U-Factor	Req. U-Factor	Prop. UA	Req. UA
Ceiling: Flat Ceiling or Scissor Truss	1,500	60.0	0.0	0.024	0.024	36	36
Wall: Wood Frame, 16" o.c.	1,440	26.0	0.0	0.052	0.045	60	52
Door: Glass Door (over 50% glazing)	42			0.320	0.320	13	13
Window 2: Vinyl Frame	250			0.320	0.320	80	80
Basement Wall: Solid Concrete or Masonry Wall height: 8.0' Depth below grade: 7.5' Insulation depth: 8.0'	1,440	0.0	15.0	0.044	0.050	61	69
Window: Vinyl Frame	64			0.320	0.320	20	20



© 2024 Shums Coda Associates 16

16

R402.1.2 Insulation and fenestration criteria

CLIMATE ZONE	FENESTRATION U-FACTOR ¹	SKYLIGHT U-FACTOR	GLAZED FENESTRATION SHGC ^{2, 3}	CEILING U-FACTOR	WOOD FRAME WALL U-FACTOR	MASS WALL U-FACTOR ³	FLOOR U-FACTOR	BASEMENT WALL U-FACTOR	CRAWL SPACE WALL U-FACTOR
0	0.50	0.75	0.25	0.035	0.084	0.197	0.064	0.360	0.477
1	0.50	0.75	0.25	0.035	0.084	0.197	0.064	0.360	0.477
2	0.40	0.65	0.25	0.026	0.084	0.165	0.064	0.360	0.477
3	0.30	0.55	0.25	0.026	0.060	0.098	0.047	0.091 ^c	0.136
4 except Marine	0.30	0.55	0.40	0.024	0.045	0.098	0.047	0.059	0.065
5 and Marine 4	0.30	0.55	0.40	0.024	0.045	0.082	0.033	0.050	0.055
6	0.30	0.55	NR	0.024	0.045	0.060	0.033	0.050	0.055
7 and 8	0.30	0.55	NR	0.024	0.045	0.057	0.028	0.050	0.055



© 2024 Shums Coda Associates

17

17

R402.1.2 Insulation and fenestration criteria

	R-value at Insulation	R-value at Stud
Air Film	00.17	00.17
Plywood Siding	00.59	00.59
1/2" Wood	00.81	00.81
1" Insulating board	03.57	03.57
R-13 Batt or wood stud	13.00	04.55
1/2" Gypsum board	00.45	00.45
Air Film	00.68	00.68
Totals	19.27	10.82

Assume a framing factor of 20% (The area of the wall that is wood)

Average R = (0.80 x 19.27) + (0.20 x 10.82) = 15.41 + 2.16 = 17.57

U-value = 1 / 17.57 = 0.057




© 2024 Shums Coda Associates

18

18

R402.1.4 R-value computation

Cavity insulation alone shall be used to determine compliance with the cavity insulation R-value requirements in Table R402.1.3. Where cavity insulation is installed in multiple layers, the R-values of the cavity insulation layers shall be summed to determine compliance with the cavity insulation R-value requirements. The manufacturer's settled R-value shall be used for blown-in insulation. Continuous insulation (ci) alone shall be used to determine compliance with the continuous insulation R-value requirements in Table R402.1.3. Where continuous insulation is installed in multiple layers, the R-values of the continuous insulation layers shall be summed to determine compliance with the continuous insulation R-value requirements. Cavity insulation R-values shall not be used to determine compliance with the continuous insulation R-value requirements in Table R402.1.3. Computed R-values shall not include an R-value for other building materials or air films. Where insulated siding is used for the purpose of complying with the continuous insulation requirements of Table R402.1.3, the manufacturer's labeled R-value for the insulated siding shall be reduced by R-0.6



© 2024 Shums Coda Associates

19

19

R405.2 Performance-based compliance

IECC COMPLIANCE METHOD:
SIMULATED PERFORMANCE PATH ALTERNATIVE (HERS)

IECC 2021 Performance Compliance

Property: _____ Organization: _____ Inspection Status: Results are projected

This report is based on a proposed design and does not confirm field enforcement of design elements.

Design	Annual Energy Cost	
	IECC 2021 Performance	As Designed
Heating	\$376	\$328
Cooling	\$98	\$124
Water Heating	\$152	\$152
Mechanical Ventilation	\$42	\$11
Sub Total - Used to determine compliance	\$668	\$613
Lights & Appliances w/out Ventilation	\$650	\$650
Onsite generation	\$0	\$0
Total	\$1,318	\$1,263

R405.3 Source Energy Exception: The proposed home uses 6.75 MBtu LESS source energy than the reference home.



20

20

Building Summary

Property: _____ Organization: _____ Inspection Status: Results are projected

General Building Information

Number Of Bedrooms	4
Number Of Floors	1
Conditioned Floor Area [sq. ft.]	2,500
Has Electric Vehicle Ready Space	No
Unconditioned, attached garage?	Yes
Conditioned Volume [cu. ft.]	27,500
Total Units in Building	5
Residence Type	Townhouse, end unit
Number of Floors in Building	1
Floor Number	1
Model	Baseline: CodeSpace Left End Unit
Community	West Village Townhomes
RESNET/IECC 2006-2018 Climate Zone	SB
IECC 2021 Climate Zone	SB

Foundation Wall

Name	Library Type	Height Above Grade	Depth Below Grade	Perimeter	Location	Enclosing
Crackspace	R-19 Draped, 4 FT	0.0	3.5	30	Exposed Exterior	Conditioned Crackspace

Foundation Wall Library List

Name	Feet From Wall Top To Continuous Insulation Top	Is Fully Insulated	Continuous R-value	Cavity R-value	Effective Insulation R-value
R-19 Draped, 4 FT	N/A	Yes	19.00	N/A	N/A

© 2024 Shums Coda Associates

21

Glazing

Name	Library Type	Wall Assignment	Foundation Wall Assignment	Is Operable	Overhang Depth	Overhang Ft To Top	Overhang Ft To Bottom	Orientation	Surface Area
Bed 2	DLUC - Vinyl	Bedding		Yes	1	7	13	West	36.0 SF
Bed 3	DLUC - Vinyl	Bedding		Yes	1	1	6	West	10.0 SF
Bed 4 Front	DLUC - Vinyl	Bedding		Yes	0	0.0	0.0	East	36.0 SF
Bed 4 side	DLUC - Vinyl	Bedding		Yes	1	20.0	24.5	South	18.0 SF
Living Family	DLUC - Vinyl	Bedding		Yes	1	10.0	16.0	South	72.0 SF
Family SUCC	DLUC - Vinyl	Bedding		Yes	0	0.0	0.0	East	64.0 SF
Family Front	DLUC - Vinyl	Bedding		Yes	1	20.0	20.0	East	9.0 SF
Kitchen	DLUC - Vinyl	Bedding		Yes	1	17	21.0	West	34.0 SF
Kitchen	DLUC - Vinyl	Bedding		Yes	1	11.0	16.0	West	13.0 SF
M Bed	DLUC - Vinyl	Bedding		Yes	1	0.0	13.0	East	36.0 SF
M Bed side	DLUC - Vinyl	Bedding		Yes	1	1	6	South	18.0 SF
M Bed South Bed 2	DLUC - Vinyl	Bedding		Yes	1	4	6	South	24.0 SF
Roof	DLUC - Vinyl	Bedding		Yes	1	0.0	4.0	East	9.0 SF
Roof door	DLUC - Vinyl	Bedding		Yes	1	0.0	10.0	South	20.0 SF
Roof side	DLUC - Vinyl	Bedding		Yes	1	0.0	7.0	South	9.0 SF
Stairs	DLUC - Vinyl	Bedding		Yes	1	0.0	4.0	East	16.0 SF
Stairs	DLUC - Vinyl	Bedding		Yes	1	10.0	14.0	East	18.0 SF

© 2024 Shums Coda Associates

22

Building Summary

Property: _____ Organization: _____ Inspection Status: Results are projected

Roof Insulation Library List

Name	Has Radiant Barrier	Effective R-value
R-42 OC Foam	No	41.500

Whole House Infiltration

Infiltration	Measurement Type	Shelter Class
2 ACH @ 50 Pa	Blower door tested	4

Mechanical Ventilation

Ventilation Type	Ventilation Rate [cfm/Min-Sq]	Operational hours per day	Fan Runs	Runs once every three hours	Energy Recovery Percent	Model Number	Manufacturer
Exhaust Only	63 CFM	24	11.3 (min)	Yes	0		

© 2024 Shums Coda Associates

23

IECC 2021 Reference Home Summary

Property: _____ Organization: _____ Inspection Status: Results are projected

General Building Information

Number Of Bedrooms	4
Number Of Floors	1
Conditioned Floor Area [sq. ft.]	2,500
Has Electric Vehicle Ready Space	No
Unconditioned, attached garage?	Yes
Conditioned Volume [cu. ft.]	27,500
Total Units in Building	5
Residence Type	Townhouse, end unit
Number of Floors in Building	1
Floor Number	1
Model	Baseline: CodeSpace Left End Unit
Community	West Village Townhomes
RESNET/IECC 2006-2018 Climate Zone	SB
IECC 2021 Climate Zone	SB

Foundation Wall

Name	Library Type	Height Above Grade	Depth Below Grade	Perimeter	Location	Enclosing
Crackspace	IECC 2021 Reference Crackspace Wall	0.0	3.5	30	Exposed Exterior	Conditioned Crackspace

Foundation Wall Library List

Name	Feet From Wall Top To Continuous Insulation Top	Is Fully Insulated	Continuous R-value	Cavity R-value	Effective Insulation R-value
IECC 2021 Reference Crackspace Wall	N/A	N/A	Yes	N/A	N/A

© 2024 Shums Coda Associates

24

2018 IECC R-406 Projected Energy Rating Index Report

Property	Organization	Energy Rating Index Information	
Builder: Best Builder In America Homes Address: 8025 Place to Live, Denver, CO 80238	Company: EnergyLogic Phone: 720-838-0677 Ruler: Robby Schwarz	Projected Rating: Rating No: Rater ID (RTR): 9124083	Date Rated: 2018-09-29

Estimated Annual Energy Consumption*			
	Rated Home Calculated Energy Use (MBtu)	Rated Home Cost (\$/yr)	
Heating	48.8	\$476	
Cooling	1.8	\$93	
Water Heating	10.2	\$97	
Lights & Appliances	22.1	\$703	
Photovoltaics	0.0	\$0	
Total	82.9	\$1,369	

*Based on average occupancy conditions.

ERI with PV/61
ERI without PV/61


Annual Estimates	
Electric (kWh): 4,262.5	CO2 Emissions (Tons): 9.8
Natural Gas (Therms): 617.0	

Minimum Energy Rating Index (61)	This Home's Energy Rating Index (61)	PASS
10	61	PASS

This home MEETS the Energy Rating Index Score requirement of 2018 IECC R-406 for Climate Zone 5. It MEETS all of the requirements verified by Ekotope. Mandatory requirements are summarized on the 2nd page of this report, some of which are not verified by Ekotope.

Name: Robby Schwarz Signature: _____
Organization: EnergyLogic Date: 11/26/19 at 2:21 PM

25



26

3. Fenestration U-factors and solar heat gain coefficients (SHGC).

WINDOW SCHEDULE

Mark	NOMINAL		Head Height	Sill Height	OPERATION	Description	U Value	Egress	Opaque dot	Tempered
	WIDTH	HEIGHT								
LOWER LEVEL T.O. CONC. SLAB										
001	6'-6"	5'-0"	14'-0 1/4"	9'-0 1/4"	CA	3050 CSMT	.32 MAX.			•
002	6'-0"	5'-0"	8'-0"	3'-0"	CA	3050 CSMT	.32 MAX.	•		
003	9'-0"	5'-0"	8'-0"	3'-0"	CA	3648 CSMT	.32 MAX.			
004	3'-0"	5'-0"	8'-0"	3'-0"	CA	3050 CSMT	.32 MAX.	•		
MAIN LEVEL										
101	7'-0"	5'-6"	8'-0"	2'-6"	CA	3656 CSMT	.32 MAX.			
102	11'-6"	3'-0"	14'-6"	11'-6"	FG	1630 FIXED	.32 MAX.		•	
103	9'-0"	6'-0"	8'-0"	2'-0"	CA	3060 CSMT/FG/CSMT	.32 MAX.			
106	6'-6"	6'-0"	12'-11 3/4"	6'-11 3/4"	CA	3060 CSMT	.32 MAX.			•
107	6'-0"	5'-0"	8'-0"	3'-0"	CA	3050 CSMT	.32 MAX.			
108	6'-0"	7'-0"	9'-0"	2'-0"	CA	3070 CSMT	.32 MAX.	•		
109	2'-0"	2'-0"	8'-6"	6'-6"	FG	2020 FIXED	.32 MAX.			
110	2'-0"	2'-0"	8'-6"	6'-6"	FG	2020 FIXED	.32 MAX.			
111	2'-0"	2'-0"	8'-6"	6'-6"	FG	2020 FIXED	.32 MAX.			
112	5'-0"	5'-0"	8'-6"	3'-6"	CA	2650 CSMT	.32 MAX.			
113	2'-0"	5'-0"	8'-0"	3'-0"	CA	2050 CSMT	.32 MAX.			
114	6'-0"	6'-0"	9'-0"	3'-0"	CA	3060 CSMT	.32 MAX.			•

27

4. Area-weighted U-factor and solar heat gain coefficients (SHGC) calculations

	#1 Value	#1 Area	#2 Value	#2 Area	#3 Value	#3 Area	Total Area	Weighted Average Value
Window U-Value	0.31	x 100	+ 0.41	x 100	+ 0.32	x 100	÷ 300	= 0.35

	#1 Value	#1 Area	#2 Value	#2 Area	#3 Value	#3 Area	Total Area	Area Weighted Average
Window SHGC	0.5	x 100	+ 0.4	x 100	+ 0.28	x 100	÷ 300	= 0.39

28

5. Mechanical system design criteria

GROUND SNOW LOAD ^a	WIND DESIGN				SEISMIC DESIGN CATEGORY ^f	SUBJECT TO DAMAGE FROM			ICE BARRIER UNDERLAYMENT REQUIRED ^h	FLOOD HAZARD ^g	AIR FREEZING INDEX ⁱ	MEAN ANNUAL TEMP ^j
	Speed ^d (mph)	Topographic effects ^k	Special wind region ^l	Windborne debris zone ^m		Weathering ^a	Frost line depth ^b	Termites ^c				
—	—	—	—	—	—	—	—	—	—	—	—	—
MANUAL J DESIGN CRITERIA ^a												
Elevation	Altitude correction factor ^a	Coincident wet bulb	Indoor winter design dry-bulb temperature	Indoor winter design dry-bulb temperature	Outdoor winter design dry-bulb temperature	Heating temperature difference						
—	—	—	—	—	—	—						
Latitude	Daily range	Indoor summer design relative humidity	Summer design gains	Indoor summer design dry-bulb temperature	Outdoor summer design dry-bulb temperature	Cooling temperature difference						
—	—	—	—	—	—	—						



© 2024 Shums Coda Associates

29

29

5. Mechanical system design criteria

Design Conditions					
Location:		Indoor:		Heating	Cooling
Denver, CO, US		Indoor temperature (°F)		70	75
Elevation: 5331 ft		Design TD (°F)		73	15
Latitude: 40°N		Relative humidity (%)		30	50
Outdoor:		Moisture difference (gr/lb)		35.3	-35.9
Dry bulb (°F)		Heating	Cooling	Infiltration:	
Daily range (°F)		-3	90	Method	
Wet bulb (°F)		-	27 (H)	Construction quality	
Wind speed (mph)		15.0	7.5	Fireplaces	
				Simplified Average	
				0	



© 2024 Shums Coda Associates

30

30

6. Mechanical and service water-heating systems and equipment types, sizes and efficiencies.

Heating Equipment Summary

Make	Carrier	Efficiency	92.1 AFUE
Trade	Carrier	Heating input	40000 Btuh
Model	58MCB040-12x	Heating output	33156 Btuh
AHRI ref	144278	Temperature rise	44 °F
		Actual air flow	830 cfm
		Air flow factor	0.031 cfm/Btuh
		Static pressure	0.70 in H2O
		Space thermostat	

Cooling Equipment Summary

Make	Carrier	Efficiency	11.0 EER, 13 SEER
Trade	BASE 13 PURONAC	Sensible cooling	18835 Btuh
Cond	24ABB324(A,W)31	Latent cooling	2765 Btuh
Coil	CAP**2414A**++TDR	Total cooling	21600 Btuh
AHRI ref	3250356	Actual air flow	995 cfm
		Air flow factor	0.067 cfm/Btuh
		Static pressure	0.70 in H2O
		Load sensible heat ratio	1.00



© 2024 Shums Coda Associates

31

31

6. Mechanical and service water-heating systems and equipment types, sizes and efficiencies.

Gas conventional (50 gal, 0.59 EF)

Manufacturer	Giant Factories, Inc.	Tank size (gal)	50
Trade name	Giant	Energy factor	0.59
Model	UG60-36LF-P1U	Input (MBtuh)	0.0
AHRI ref. number	463306	1st hour (gal)	86
		Recovery eff. (%)	80



© 2024 Shums Coda Associates

32

32

7. Equipment and system controls.

T&B	TOP AND BOTTOM
TBC	TOP OF BACK OF CURB
TEL	TELEPHONE
TEM	TEMPERED
TEMP	TEMPERATURE
T&G	TONGUE AND GROOVE
THERM	THERMOSTAT
THK	THICK
THLD	THRESHOLD
TO	TOP OF
TOC	TOP OF CONCRETE
TOS	TOP OF STEEL
TOSL	TOP OF SLAB
TOW	TOP OF WALL
TV	TELEVISION
TYP	TYPICAL

R403.1.1 Programmable thermostat

R403.1.2 Heat pump supplementary heat

R403.2 Hot water boiler temperature reset



© 2024 Shums Code Associates

33

33

8. Duct sealing, duct and pipe insulation and location.

Ventilation Testing: Mech. ventilation systems shall be tested and verified to provide the minimum ventilation flow rates reuired by Section N1103.6.

Hot Water Pipe Insulation (Prescriptive): Insulation for hot water pipe with a minimum thermal resistance (R-value) of R-3 shall be applied to the following:

- A. Piping larger than 3/4" nominal diameter.
- B. Piping from the water heater to kitchen outlets.
- C. Piping located outside the conditioned space.
- D. Piping from the water heater to a distribution manifold.
- E. Piping located under a floor slab.
- F. Buried piping.
- G. Supply and return piping in recirculation systems other than demand recirculation.
- H. Piping with run lengths greater than the maximum run lengths for the nominal pipe diameter given in the following table


Duct Testing: Rough-in test: total leakage shall be measured with a pressure differential of 0.1" w.g. (25 Pa) across the system, including the manuf. air handler enclosure if installed at the time of the test. Registers shall be taped or otherwise sealed during the test. Per N1103.3.5

© 2024 Shums Code Associates

34

34

9. Air sealing details




© 2024 Shums Code Associates

35

35


9. Air sealing details




© 2024 Shums Code Associates

36


36




37




38




39




40




41




42




43




44



45




46



47



48



49

R402.2.12 Sunroom and heated garage insulation

Sunrooms enclosing conditioned space and heated garages shall meet the insulation requirements of this code.

Exception

For sunrooms and heated garages provided thermal isolation, and enclosed conditioned space, the following exceptions to the insulation requirements of this code shall apply:

1. The minimum ceiling insulation R-values shall be R-19 in Climate Zones 0 through 4 and R-24 in Climate Zones 5 through 8.
2. The minimum wall insulation R-value shall be R-13 in all climate zones. Walls separating a sunroom or heated garage with thermal isolation from conditioned space shall comply with the building thermal envelope requirements of this code.

© 2024 Shums Coda Associates

50

R403.6 Mechanical ventilation

The buildings complying with Section R402.4.1 shall be provided with ventilation that complies with the requirements of Section M1505 of the International Residential Code or International Mechanical Code, as applicable, or with other approved means of ventilation. Outdoor air intakes and exhausts shall have automatic or gravity dampers that close when the ventilation system is not operating

© 2024 Shums Coda Associates

51

M1505.4.3 Mechanical ventilation rate

TABLE M1505.4.3(1) CONTINUOUS WHOLE-HOUSE MECHANICAL VENTILATION SYSTEM AIRFLOW RATE REQUIREMENTS

DWELLING UNIT FLOOR AREA (square feet)	NUMBER OF BEDROOMS				
	0-1	2-3	4-5	6-7	> 7
	Airflow in CFM				
< 1,500	30	45	60	75	90
1,501-3,000	45	60	75	90	105
3,001-4,500	60	75	90	105	120
4,501-6,000	75	90	105	120	135
6,001-7,500	90	105	120	135	150
> 7,500	105	120	135	150	165

Ventilation rate in cubic feet per minute =
 $(0.01 \times \text{total square foot area of house}) + [7.5 \times (\text{number of bedrooms} + 1)]$

© 2024 Shums Coda Associates

52

Exceptions:

1. Ventilation rate credit. The minimum mechanical ventilation rate determined in accordance with Table M1505.4.3(1) or Equation 15-1 shall be reduced by 30 percent, provided that both of the following conditions apply:
 - 1.1. A ducted system supplies ventilation air directly to each bedroom and to one or more of the following rooms:
 - 1.1.1. Living room.
 - 1.1.2. Dining room.
 - 1.1.3. Kitchen.
 - 1.2. The whole-house ventilation system is a balanced ventilation system.
2. Programmed intermittent operation. The whole-house mechanical ventilation system is permitted to operate intermittently where the system has controls that enable operation for not less than 25 percent of each 4-hour segment and the ventilation rate prescribed in Table M1505.4.3(1), by Equation 15-1 or by Exception 1 is multiplied by the factor determined in accordance with Table M1505.4.3(2)

© 2024 Shums Coda Associates

53

53

TABLE M1505.4.3(2) INTERMITTENT WHOLE-HOUSE MECHANICAL VENTILATION RATE FACTORS

RUN-TIME PERCENTAGE IN EACH 4-HOUR SEGMENT	25%	33%	50%	66%	75%	100%
Factor ^a	4	3	2	1.5	1.3	1.0

a. For ventilation system run-time values between those given, the factors are permitted to be determined by interpolation.


b. Extrapolation beyond the table is prohibited.



© 2024 Shums Coda Associates

54

54



© 2024 Shums Coda Associates

55

55

Exhaust Only Whole House Ventilation System

An exhaust only ventilation strategy can be as simple as an exhaust fan that runs continuously or at timed intervals

Advantages:

- Low Cost and easy to install
- Can use infiltration
- Work well in cold climates

Disadvantages:

- May cause combustion spillage from combustion appliances (Natural Draft type)
- Not appropriate for hot humid climates
- Rely in part on random air leakage




© 2024 Shums Coda Associates

56

56

Supply Only Whole House Ventilation System



A supply only system can be as simple as connecting an outside air duct to the return air duct



© 2024 Shums Coda Associates

57

57

Supply Only Whole House Ventilation System

Advantages:

- Low cost and easily installed
- Will not cause negative pressure that could affect combustion appliances
- Allow filtering of pollen and dust in outdoor air
- Allow dehumidification of outdoor air
- Works in hot or mixed climates



© 2024 Shums Coda Associates

58

58

Supply Only Whole House Ventilation System

Disadvantages:

Positive pressure could push moisture into the building envelope

In cold climates if not preheating air, mixed air temperatures could be a problem when using forced air furnace for distribution and outside air duct must be insulated to prevent condensation

In humid climates increased cooling loads (Latent loads)

Can increase heating and cooling costs



© 2024 Shums Coda Associates

59

59

Supply Only Whole House Ventilation System



© 2024 Shums Coda Associates

60

60

Supply Only Whole House Ventilation System

So how much outside air is too much?????

The code has no guidance, and the manufacturers simply say the furnace temperature rise must be within a specified range.

Generally, the outside air flow (cfm) should not be more than 10% of the furnace flow and the outside air duct should be a minimum of 8' to 10' from the heat exchanger.



© 2024 Shums Coda Associates

61

61

Supply Only Whole House Ventilation System

So here is the math for at least idea of the mixed air temperature:

$(\text{Return Air Temperature} \times 0.9) + (\text{Outside air temperature} \times 0.1) \approx \text{mixed Air Temperature}$

We will assume a return air is 68° and the outside air is - 25°

Solve:

$$(68 * 0.9) + (-25 * 0.1)$$

$$61.2 + -2.5 = 58.7^\circ \text{ for an approximate mixed air temperature}$$




© 2024 Shums Coda Associates

62

62

SEMI-BALANCED WHOLE HOUSE VENTILATION SYSTEM



© 2024 Shums Coda Associates

63

63

BALANCED WHOLE HOUSE VENTILATION SYSTEM

Semi Balanced

Advantages:

Appropriate for all climate zone

Disadvantages:

Can cost more to install and operate than exhaust or supply systems

Does not temper or remove moisture from incoming air

Can increase heating and cooling costs




© 2024 Shums Coda Associates

64

64

BALANCED WHOLE HOUSE VENTILATION SYSTEM



Balanced HRV or ERV



© 2024 Shums Coda Associates

65

65

BALANCED WHOLE HOUSE VENTILATION SYSTEM

Advantages:

- Reduce heating and cooling costs
- Available as either small wall- or window-mounted models or central ventilation systems
- Cost-effective in climates with extreme winters or summers and high fuel costs.



© 2024 Shums Coda Associates

66

66

BALANCED WHOLE HOUSE VENTILATION SYSTEM

Disadvantages:

- Can cost more to install than other ventilation systems
- May not be cost-effective in mild climates
- Require freeze and frost protection in cold climates
- Require more maintenance than other ventilation systems.




© 2024 Shums Coda Associates

67

67

Balanced

- Heat Recovery Ventilator (HRV)
- or
- Energy Recovery Ventilator (ERV)




© 2024 Shums Coda Associates

68

68

R403.7 Equipment sizing and efficiency rating

Heating and cooling equipment shall be sized in accordance with ACCA Manual S based on building loads calculated in accordance with ACCA Manual J or other approved heating and cooling calculation methodologies. New or replacement heating and cooling equipment shall have an efficiency rating equal to or greater than the minimum required by federal law for the geographic location where the equipment is installed.



© 2024 Shums Coda Associates

69

69

Design conditions must be correct

Weather: Denver, CO, US

Winter Design Conditions		Summer Design Conditions	
Outside db	-3 °F	Outside db	90 °F
Inside db	70 °F	Inside db	75 °F
Design TD	73 °F	Design TD	15 °F
		Daily range	H
		Relative humidity	50 %
		Moisture difference	-35 gr/lb



© 2024 Shums Coda Associates

70

70

DESIGN LOADS

Ducts with no load would be located entirely inside the buildings thermal barrier. Central vent is the result of ventilation air.

Heating Summary	
Structure	28273 Btuh
Ducts	0 Btuh
Central vent (64 cfm)	4213 Btuh
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	32486 Btuh



© 2024 Shums Coda Associates

71

71

DESIGN LC

Infiltration

Method	Heating	Cooling
Construction quality	3600	3600
Fireplaces	0	0
	Heating	Cooling
Area (ft ²)	3600	3600
Volume (ft ³)	14464	14464
Air changes/hour	0.28	0.15
Equiv. AVF (cfm)	67	36



Heating Summary	
Structure	28273 Btuh
Ducts	0 Btuh
Central vent (64 cfm)	4213 Btuh
Humidification	0 Btuh
Piping	0 Btuh
Equipment load	32486 Btuh

- Solve for today's house
- $.35 \times 14,464 / 60 = 84$
 - $20 \times 5 = 100$
 - $0.50 \times 40,000 / 1000 = 20$
- 100 cfm - 36 cfm = 64 cfm

- General ventilation $0.35 \times$ above grade volume of conditioned space/ 60
- Occupant ventilation Minimum ventilation per person \times Number of occupants
- Combustion air requirements $0.50 \times$ input capacity of furnace with atmospheric burner/1000




© 2024 Shums Coda Associates

72

72

DESIGN LOADS




Infiltration

Method	Simplified Average	
Construction quality	0	
Fireplaces	0	
	Heating	Cooling
Area (ft ²)	3600	3600
Volume (ft ³)	14464	14464
Air changes/hour	0.28	0.15
Equiv. AVF (cfm)	67	36

Volume is the above grade volume

Air changes /hour for heating is done with a 15 mph wind and 7.5 mph for cooling

AVF = Air Volume Flow



© 2024 Shums Coda Associates


73

73

DESIGN LOADS



Sensible Load

The heat gain of the home due to conduction, solar radiation, infiltration, appliances, people and pets. Burning a light bulb, for example, adds only sensible load to the house. The sensible load raises the dry-bulb temperature.



Sensible Cooling Equipment Load Sizing

Structure	14954	Btuh
Ducts	0	Btuh
Central vent (64 cfm)	877	Btuh
Blower	0	Btuh
Use manufacturer's data	y	
Rate/swing multiplier	1.00	
Equipment sensible load	15832	Btuh

© 2024 Shums Coda Associates

74


74

DESIGN LOADS

Latent Cooling Load

The net amount of moisture added to the inside air by people, plants, cooking, infiltration and any other moisture source.

SHR = Sensible Heat Ratio
The ratio of sensible load to total load




Example House

15,832/ 15,832 = 1.00

So why are we using .85 ???

Latent Cooling Equipment Load Sizing

Structure	274	Btuh
Ducts	0	Btuh
Central vent (64 cfm)	-1281	Btuh
Equipment latent load	0	Btuh
Equipment total load	15832	Btuh
Req. total capacity at 0.85 SHR	1.6	ton



© 2024 Shums Coda Associates

75

75

Sensible Heat Equation to calculate a preliminary cooling CFM

CFM = Sensible Load / (1.1 x ACF x ΔT)

Where:


- Sensible Load** (Btuh) is the sensible cooling load from the MJ8 load calculation.
- CFM** (cubic feet per minute) is the volume of the air moving through the furnace and the indoor cooling coil.
- 1.1** is a physical constant for the equation.
- ACF** (altitude correction factor) is the adjustment for air density at the local altitude.
- ΔT** is the temperature difference in the air between the inlet and the outlet furnace/cooling coil.

We will use the table from Manual S.

- A high SHR will have a low or negative latent load (like Denver)
- A low SHR will have a large latent load (like Florida)
- Math for Today CFM = 15,832 / (1.1 x .832 x 17) = 1,017 cfm

Sensible Heat Ratio vs. Cooling Coil Temperature Difference (ΔT)	
JSHR	ΔT
Below 0.80	21° F
0.80 - 0.85	19° F
Above 0.85	17° F

ΔT = Entering Dry Bulb - Leaving Dry Bulb



© 2024 Shums Coda Associates

76

76

DESIGN LOADS

Design Information

Weather: Denver, CO, US

Winter Design Conditions		Summer Design Conditions	
Outside db	-3 °F	Outside db	90 °F
Inside db	70 °F	Inside db	75 °F
Design TD	73 °F	Design TD	15 °F
		Daily range	H
		Relative Humidity	50 %
		Moisture difference	-36 gr/lb

Heating Summary		Sensible Cooling Equipment Load Sizing	
Structure	26853 Btuh	Structure	14954 Btuh
Ducts	0 Btuh	Ducts	0 Btuh
Central vent (64 cfm)	4213 Btuh	Central vent (64 cfm)	877 Btuh
Humidification	0 Btuh	Blower	0 Btuh
Piping	0 Btuh		
Equipment load	31066 Btuh	Use manufacturer's data	Y
		Rate/sizing multiplier	1.00
		Equipment sensible load	15832 Btuh

Infiltration		Latent Cooling Equipment Load Sizing	
Method	Simplified	Structure	274 Btuh
Construction quality	Average	Ducts	0 Btuh
Fireplaces	0	Central vent (64 cfm)	-1281 Btuh
		Equipment latent load	0 Btuh
		Equipment total load	15832 Btuh
		Req. total capacity at 0.85 SHR	1.8 ton

	Heating	Cooling
Area (ft²)	3600	3600
Volume (ft³)	14464	14464
Air changes/hour	0.28	0.15
Equiv. A/VF (cfm)	67	36

© 2024 Shums Coda Associates
77

77

DESIGN LOADS

Construction descriptions

	Or	Area	U-value	Insul R	Htg HTM	Loss	Cig HTM	Gain
		ft²	ft²-Btu/h-°F	ft²-Ft/Btu	Btu/h-ft²	Btu/h	Btu/h-ft²	Btu/h
Walls								
12F-0sw Firm wall, wd ext, 1/2" wood shth, r-21 cav ins, 1/2" gypsum board int trsh, 2"x6" wood frm								
15B13-0wc-8 Bg wall, light dry soil, 2"x4" wood int frm, concrete wall, r-13 cav ins, 6" blk, 1/2" gypsum board int trsh								
Partitions								
12E-0sw Firm wall, wd ext, 1/2" wood shth, r-19 cav ins, 1/2" gypsum board int trsh, 2"x6" wood frm	243	0.068	19.0	2.38	578	1.02	248	
Windows								
Low E u-32 SHGC 40: 1 glazing, cr gtz, mtl no brk frm mat, 1/8" blk, NFRC rated (SHGC=0.40); 50% blinds 45°, medium; 50% outdoor insect screen, 2 ft overhang (3 ft window ft, 2 ft sep.)								

There are hundreds of construction descriptions. They should match the construction plans.

A Partition is a wall that separates a conditioned area from an unconditioned area. This would be typical of a wall between the house and the garage.

Verify that the designer has taken credit for blinds, screens and overhangs.

© 2024 Shums Coda Associates
78

78

DESIGN LOADS

Construction descriptions	Or	Area	U-value	Insul R	Htg HTM	Loss	Cig HTM	Gain
		ft²	ft²-Btu/h-°F	ft²-Ft/Btu	Btu/h-ft²	Btu/h	Btu/h-ft²	Btu/h
Walls								
12F-0sw Firm wall, wd ext, 1/2" wood shth, r-21 cav ins, 1/2" gypsum board int trsh, 2"x6" wood frm	ne	254	0.065	21.0	4.74	1205	0.78	199
	se	223	0.065	21.0	4.74	1058	0.78	175
	sw	242	0.065	21.0	4.74	1148	0.78	190
	nw	388	0.065	21.0	4.74	1841	0.78	304
	all	1107	0.065	21.0	4.74	5253	0.78	867

2x6 STUDS; RE: STRUCTURAL

5/8" TYPE N GYPSUM WALL BOARD; TYP., U.N.O. INTERIOR

BATT INSULATION; R-21 WITH VAPOR BARRIER to WARM SIDE

SILL SEAL FOAM GASKET MATERIAL; TYP.

SILL PLATE; 2x6, TREATED, TYP.

© 2024 Shums Coda Associates
79

79

DESIGN LOADS


Construction descriptions	Or	Area	U-value	Insul R	Htg HTM	Loss	Cig HTM	Gain
		ft²	ft²-Btu/h-°F	ft²-Ft/Btu	Btu/h-ft²	Btu/h	Btu/h-ft²	Btu/h
Walls								
12F-0sw Firm wall, wd ext, 1/2" wood shth, r-21 cav ins, 1/2" gypsum board int trsh, 2"x6" wood frm	ne	254	0.065	21.0	4.74	1205	0.78	199
	se	223	0.065	21.0	4.74	1058	0.78	175
	sw	242	0.065	21.0	4.74	1148	0.78	190
	nw	388	0.065	21.0	4.74	1841	0.78	304
	all	1107	0.065	21.0	4.74	5253	0.78	867
	ne	236	0.049	13.0	3.30	780	0	0
	se	448	0.049	13.0	3.58	1602	0	0
	sw	216	0.049	13.0	2.98	644	0	0
	nw	388	0.049	13.0	3.08	1195	0	0
	all	1288	0.049	13.0	3.28	4222	0	0
Partitions								
12E-0sw Firm wall, wd ext, 1/2" wood shth, r-19 cav ins, 1/2" gypsum board int trsh, 2"x6" wood frm								
Windows								

In Wrightsoft there is a command to turn the house in the direction with the highest loads. It is not unusual for production builders to do this.


HTM = Heat Transfer Modifier
All of the Manual J formulas boil down to an HTM. The HTM times the area equals the heat loss or gain.

© 2024 Shums Coda Associates
80

80



81



82

DESIGN LOADS

6	c) AED excursion				1812			523
	Envelope loss/gain			22399	10908		3450	2236
12	a) Infiltration			4454	497		1177	131
	b) Room ventilation			0	0		0	0
13	Internal gains:	Occupants @	230	0	1150	0		0
		Appliances/other			2400			0
	Subtotal (lines 6 to 13)			26953	14954		4627	2367
	Less external load			0	0		0	0
	Less transfer			0	0		0	0
	Redistribution			0	0		231	70
14	Subtotal			26953	14954		4858	2437
15	Duct loads		0%	0%	0	-0%	0%	0
	Total room load			26953	14954		4858	2437
	Air required (cfm)			830	995		150	162

© 2024 Shums Coda Associates 83

83

DESIGN LOADS


- Adequate Exposure Diversity

According to Manual J 8 procedures, a zone is defined as having Adequate Exposure Diversity (AED) if the maximum hourly glazing load (PFG) does not exceed the average glazing load (AFG) by more than 30%. The amount over 30% of the AFG is defined as the AED Excursion.

© 2024 Shums Coda Associates 84

84

DESIGN LOADS



© 2024 Shums Coda Associates

85

85

DESIGN LOADS

- Questions on design loads ?

Project Information	
For:	Colorado ED Inst. March 2012
Notes:	
Design Information	
Weather: Denver, CO, US	
Winter Design Conditions	Summer Design Conditions
Outside db: -3 °F	Outside db: 90 °F
Inside db: 70 °F	Inside db: 75 °F
Design TD: 73 °F	Design TD: 15 °F
	Daily range: 75
	Relative humidity: 50 %
	Moisture difference: -36 gr/lb
Heating Summary	Sensible Cooling Equipment Load Sizing
Structure: 26853 Btuh	Structure: 14954 Btuh
Ducts: 0 Btuh	Ducts: 0 Btuh
Central vent (64 cfm): 4213 Btuh	Central vent (64 cfm): 877 Btuh
Humidification: 0 Btuh	Boiler: 0 Btuh
Piping: 0 Btuh	Use manufacturer's data: Y
Equipment load: 31066 Btuh	Rate/weight multiplier: 1.00
Infiltration	Latent Cooling Equipment Load Sizing
Method: Simplified	Structure: 274 Btuh
Construction quality: Average	Ducts: 0 Btuh
Fireplaces: 0	Central vent (64 cfm): -1281 Btuh
	Equipment latent load: 0 Btuh
Area (ft²): Heating 3600 Cooling 3600	Equipment total load: 15632 Btuh
Volume (ft³): 14464 14464	Req. total capacity at 0.85 SHR: 1.6 ton
Air changes (ACH): 2024 Shums Coda Associates 0.15	
Equip. AVE (cfm): 67 36	



© 2024 Shums Coda Associates

86

86

Equipment Selection **Heating**

The required load (Heat Loss) on our example house is 31,066 Btuh.

I have selected a Carrier (No reason but that I had all the performance specifications) model 58MCB 040-12.

This unit has a 40,000 Btuh input rating and has an efficiency rating of 92.1 AFUE.

..\\..\\Carrier Equipment\\Carrier - 58MCB - Product Data.pdf



© 2024 Shums Coda Associates

87

87

Equipment Selection **Heating**

The output rating will be about 33,156 Btuh after de-rating for efficiency and for altitude.

$$40,000 \times .921 = 36,840 \times .90 = 33,156 \text{ Btuh}$$

So what is the correct adjustment for altitude?? Manual S does have generic deration factors but only if the manufacturer does not provide any deration information. See the footnotes in the performance data.

Per Manual S it is acceptable to size up to 140% the MJ8 required load

$$31,066 \times 1.4 = 43,492 > 33,156 \text{ Btuh}$$



© 2024 Shums Coda Associates

88

88

Equipment Selection **Heating**

Performance data

UNIT SIZE	040-08	040-12	040-08	060-12	060-16	060-12	080-16	080-20	100-16	100-20	120-20	140-20
CERTIFIED TEMP RISE RANGE (°F)	30-60	15-45	25-75	35-60	25-50	40-70	30-60	20-50	45-75	30-60	40-70	50-80
CERTIFIED EXT STATIC PRESSURE Heating	0.10	0.10	0.12	0.12	0.12	0.15	0.15	0.15	0.20	0.20	0.20	0.20
(In. w.c.) Cooling	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50
AIRFLOW CFM Heating	850	1125	885	1265	1320	1190	1295	1780	1915	1690	1720	1970
Cooling	895	1215	900	1200	1545	1245	1525	1925	1570	1930	2000	1990

EFFICIENCY

UNIT SIZE	040-08	040-12	060-08	060-12	060-16	080-12	080-16	080-20	100-16	100-20	120-20	140-20																																																																														
OUTPUT CAPACITY BTUH (ICS)	<table border="1"> <tr> <td>Direct Vent (2-Pipe)</td> <td>Upflow</td> <td>37,000</td> <td>37,000</td> <td>56,000</td> <td>56,000</td> <td>56,000</td> <td>74,000</td> <td>74,000</td> <td>74,000</td> <td>93,000</td> <td>93,000</td> <td>112,000/127,000</td> </tr> <tr> <td>Downflow</td> <td>37,000</td> <td>37,000</td> <td>56,000</td> <td>56,000</td> <td>56,000</td> <td>74,000</td> <td>74,000</td> <td>74,000</td> <td>93,000</td> <td>93,000</td> <td>112,000/127,000</td> <td>NA</td> </tr> <tr> <td>Horizontal</td> <td>37,000</td> <td>37,000</td> <td>56,000</td> <td>56,000</td> <td>56,000</td> <td>74,000</td> <td>74,000</td> <td>74,000</td> <td>93,000</td> <td>93,000</td> <td>112,000/127,000</td> <td>NA</td> </tr> <tr> <td>Non-Direct Vent (1-Pipe)</td> <td>Upflow</td> <td>37,000</td> <td>37,000</td> <td>56,000</td> <td>56,000</td> <td>56,000</td> <td>74,000</td> <td>74,000</td> <td>74,000</td> <td>93,000</td> <td>93,000</td> <td>112,000/NA</td> </tr> <tr> <td>Downflow</td> <td>37,000</td> <td>37,000</td> <td>56,000</td> <td>56,000</td> <td>56,000</td> <td>74,000</td> <td>74,000</td> <td>74,000</td> <td>93,000</td> <td>93,000</td> <td>112,000/NA</td> <td>NA</td> </tr> <tr> <td>Horizontal</td> <td>37,000</td> <td>37,000</td> <td>56,000</td> <td>56,000</td> <td>56,000</td> <td>74,000</td> <td>74,000</td> <td>74,000</td> <td>93,000</td> <td>93,000</td> <td>112,000/NA</td> <td>NA</td> </tr> </table>												Direct Vent (2-Pipe)	Upflow	37,000	37,000	56,000	56,000	56,000	74,000	74,000	74,000	93,000	93,000	112,000/127,000	Downflow	37,000	37,000	56,000	56,000	56,000	74,000	74,000	74,000	93,000	93,000	112,000/127,000	NA	Horizontal	37,000	37,000	56,000	56,000	56,000	74,000	74,000	74,000	93,000	93,000	112,000/127,000	NA	Non-Direct Vent (1-Pipe)	Upflow	37,000	37,000	56,000	56,000	56,000	74,000	74,000	74,000	93,000	93,000	112,000/NA	Downflow	37,000	37,000	56,000	56,000	56,000	74,000	74,000	74,000	93,000	93,000	112,000/NA	NA	Horizontal	37,000	37,000	56,000	56,000	56,000	74,000	74,000	74,000	93,000	93,000	112,000/NA	NA
Direct Vent (2-Pipe)	Upflow	37,000	37,000	56,000	56,000	56,000	74,000	74,000	74,000	93,000	93,000	112,000/127,000																																																																														
Downflow	37,000	37,000	56,000	56,000	56,000	74,000	74,000	74,000	93,000	93,000	112,000/127,000	NA																																																																														
Horizontal	37,000	37,000	56,000	56,000	56,000	74,000	74,000	74,000	93,000	93,000	112,000/127,000	NA																																																																														
Non-Direct Vent (1-Pipe)	Upflow	37,000	37,000	56,000	56,000	56,000	74,000	74,000	74,000	93,000	93,000	112,000/NA																																																																														
Downflow	37,000	37,000	56,000	56,000	56,000	74,000	74,000	74,000	93,000	93,000	112,000/NA	NA																																																																														
Horizontal	37,000	37,000	56,000	56,000	56,000	74,000	74,000	74,000	93,000	93,000	112,000/NA	NA																																																																														
INPUT BTUH	40,000	40,000	60,000	60,000	60,000	80,000	80,000	80,000	100,000	100,000	120,000	120,000																																																																														
AFUE% Direct Vent (2-Pipe)	Upflow	92.3	92.3	92.3	92.3	92.3	92.3	92.3	92.3	92.3	92.3	92.3																																																																														
Downflow	91.2	91.2	91.2	91.2	91.2	91.2	91.2	91.2	91.2	91.2	91.2	91.2																																																																														
Horizontal	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1																																																																														
Non-Direct Vent (1-Pipe)	Upflow	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1	92.1																																																																														
Downflow	91.0	91.0	91.0	91.0	91.0	91.0	91.0	91.0	91.0	91.0	91.0	91.0																																																																														
Horizontal	91.0	91.0	91.0	91.0	91.0	91.0	91.0	91.0	91.0	91.0	91.0	91.0																																																																														

* Capacity and AFUE in accordance with U.S. Government DOE test procedures.
 † Gas input ratings are certified for elevations to 2000 ft. For elevations above 2000 ft, reduce ratings 2% for each 1000 ft above sea level. In Canada, derate the unit 5% for elevations 2000 to 4500 ft above sea level.
 ‡ Airflow shown is for bottom only return-air supply. For air delivery above 1800 CFM, see Air Delivery table for other options. A filter is required for each return-air supply.
 ICS—Isolated Combustion System



© 2024 Shums Coda Associates

Equipment Selection **Heating**

Method Construction quality
 Fireplaces Simplified Average 0

	Heating	Cooling
Area (ft²)	3600	3600
Volume (ft³)	14464	14464
Air changes/hour	0.28	0.15
Equiv. AVF (cfm)	67	36

Heating Equipment Summary

Make Carrier
 Trade Carrier
 Model 58MCB040-12x
 AHRI ref no. 144278

Efficiency	92.1 AFUE
Heating input	40000 Btuh
Heating output	33156 Btuh
Temperature rise	44 °F
Actual air flow	830 cfm
Air flow factor	0.031 cfm/Btuh
Static pressure	0.70 in H2O
Space thermostat	

Temperature Rise:
 The difference in the air temperature entering the heat exchanger and the air leaving the heat exchanger.
 Heat (temperature) Rise Formula:
 Btuh/cfm (1.1xACF) = Temperature Rise
 Where:
 Btuh = Heating output
 CFM = Actual Air Flow in Cubic Feet per Minute
 1.1 is a formula constant at sea level
 ACF = Altitude Correction Factor from Table 10A (5000' = .832)
 33,156/830/(1.1x.832) = 43.6 degrees F



© 2024 Shums Coda Associates

Equipment Selection **Heating**

Temperature Rise is the difference in the return air entering heat exchanger and the air leaving the heat exchanger.



© 2024 Shums Coda Associates

Equipment Selection **Heating**

Heating Equipment Summary

Make Carrier
 Trade Carrier
 Model 58MCB040-12x
 AHRI ref no. 144278

Efficiency	92.1 AFUE
Heating input	40000 Btuh
Heating output	33156 Btuh
Temperature rise	44 °F
Actual air flow	830 cfm
Air flow factor	0.031 cfm/Btuh
Static pressure	0.70 in H2O
Space thermostat	

Actual Air flow is from the manufacturers performance data at a specific static pressure



© 2024 Shums Coda Associates

Equipment Selection Heating

Performance data

UNIT SIZE:		040-08	040-12	060-08	060-12	060-16	080-12	080-16	080-20	100-16	100-20	120-20
CERTIFIED TEMP RISE RANGE (°F)		30-60	15-45	5-75	30-60	20-50	40-70	30-60	20-50	45-75	30-60	40-70
CERTIFIED EXT STATIC PRESSURE (In. wc)	Heating	0.10	0.10	0.12	0.12	0.12	0.15	0.15	0.15	0.20	0.20	0.20
	Cooling	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50	0.50
AIRFLOW CFM:	Heating	850	1125	885	1065	1320	1190	1285	1785	1315	1690	1720
	Cooling	895	1215	900	1200	1545	1245	1525	1925	1570	1930	2000

AIR DELIVERY—CFM (With Filter)*		EXTERNAL STATIC PRESSURE (In. wc)									
UNIT SIZE	RETURN-AIR SUPPLY	SPEED	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	
040-08	1 side or bottom	High	1075	1040	995	945	895	840	790	740	670
		Med-Low	850	825	790	740	695	635	590	540	480
		Low	740	720	690	650	615	565	515	465	385
040-12	1 side or bottom	High	1470	1415	1400	1385	1215	1120	995	890	890
		Med-High	1215	1200	1205	1180	1115	1035	930	825	825
		Med-Low	1125	1110	1085	1045	960	915	830	740	740
060-08	1 side or bottom	High	1100	1055	1055	945	900	805	730	670	670
		Med-Low	890	865	810	765	720	625	540	475	475
		Low	745	710	670	625	565	520	425	360	360
080-12	1 side or bottom	High	1430	1375	1325	1275	1200	1135	1040	935	935
		Med-High	1270	1260	1215	1160	1105	1035	950	860	860
		Med-Low	1070	1055	1045	1015	975	920	850	750	750
060-16	1 side or bottom	High	1700	1695	1640	1580	1525	1450	1380	1310	1310
		Med-High	1500	1495	1435	1385	1330	1260	1205	1135	1135
		Med-Low	1325	1295	1265	1230	1190	1150	1105	1050	1050
080-12	1 side or bottom	High	1525	1470	1425	1370	1315	1260	1190	1120	1120
		Med-High	1395	1350	1300	1235	1155	1080	1005	930	930
		Med-Low	1265	1175	1125	1065	1020	970	900	830	830
080-12	1 side or bottom	High	1700	1685	1635	1575	1520	1445	1380	1310	1310
		Med-High	1500	1485	1435	1375	1320	1245	1180	1110	1110
		Med-Low	1325	1295	1265	1230	1190	1150	1105	1050	1050

Equipment Selection Heating

Questions on Heating equipment selection ?

Heating Equipment Summary

Make Carrier
 Trade Carrier
 Model 58MCB040-12x
 AHRI ref no. 144278

Efficiency 92.1 AFUE
 Heating input 40000 Btuh
 Heating output 33156 Btuh
 Temperature rise 44 °F
 Actual air flow 830 cfm
 Air flow factor 0.031 cfm/Btuh
 Static pressure 0.70 in H2O
 Space thermostat



Equipment Selection Cooling

Cooling Equipment Summary

Make Carrier
 Trade BASE 13 PURON AC
 Cond 24ABB324(A,W)31
 Coil CAP**2414A**++TDR
 AHRI ref no. 3250356
 Efficiency 11.0 EER, 13 SEER
 Sensible cooling 18835 Btuh
 Latent cooling 2765 Btuh
 Total cooling 21600 Btuh
 Actual air flow 995 cfm
 Air flow factor 0.067 cfm/Btuh
 Static pressure 0.70 in H2O
 Load sensible heat ratio 1.00

..\\..\\Carrier Equipment\\24abb3-7pd.pdf



Equipment Selection Cooling

- Earlier we concluded that the MJ8 sensible heat ratio (JSHR) was 1.00
- The intent is to pick cooling equipment with the same (or as close as we can) SHR at a specified cfm.



Equipment Selection Cooling

Our target loads:
 Total = 15,832 Btuh Sensible = 15,832 Btuh Latent = 0.00 Btuh

DETAILED COOLING CAPACITIES# CONTINUED

EVAPORATOR AIR		CONDENSER ENTERING AIR											
CFM	EWB °F (°C)	75 (23.9)				85 (29.4)				95 (35)			
		Capacity MBtuh		Total Systems KW**	Total Sensit	Capacity MBtuh		Total Systems KW**	Total Sensit	Capacity MBtuh		Total Systems KW**	Total Sensit
700	72 (22.2)	27.09	13.27	1.65		23.82	12.82	1.85		24.83	12.41	2.06	
	67 (19.4)	24.89	16.41	1.65	23.83	15.99	1.84	22.71	15.56	2.05	23.83	15.99	1.84
	63 (17.2)††	23.39	15.58	1.84	22.38	15.55	1.84	21.29	15.11	2.05	23.39	15.58	1.84
	62 (16.7)	23.01	15.56	1.84	22.03	15.14	1.84	20.99	14.67	2.05	23.01	15.56	1.84
	57 (13.9)	22.46	22.46	1.84	21.66	21.66	1.83	20.79	20.79	2.05	22.46	22.46	1.84
	72 (22.2)	27.52	13.92	1.89	26.15	13.46	1.88	24.91	13.04	2.10	27.52	13.92	1.89
	67 (19.4)	25.25	17.44	1.88	24.16	17.03	1.88	23.00	16.60	2.09	25.25	17.44	1.88
	63 (17.2)††	23.76	16.95	1.88	22.72	16.53	1.87	21.80	16.08	2.09	23.76	16.95	1.88
	62 (16.7)	23.47	20.89	1.88	22.49	20.52	1.87	21.52	21.52	2.09	23.47	20.89	1.88
	57 (13.9)	23.30	23.30	1.88	22.44	22.44	1.87	21.33	21.33	2.09	23.30	23.30	1.88

We will start with 800 cfm value. (We will adjust for altitude later)

EWB = Entering Wet Bulb temperature. We will use the 63° value
 (Close enough & see footnote)

Remember we said that 75° dry bulb at 50% RH is psychrometrically equal to 62° wet bulb.



Equipment Selection Cooling

DETAILED COOLING CAPACITIES# CONTINUED

EVAPORATOR AIR		CONDENSER ENTERING AIR											
CFM	EWB °F (°C)	75 (23.9)				85 (29.4)				95 (35)			
		Capacity MBtuh		Total Systems KW**	Total Sensit	Capacity MBtuh		Total Systems KW**	Total Sensit	Capacity MBtuh		Total Systems KW**	Total Sensit
700	72 (22.2)	27.09	13.27	1.65		23.82	12.82	1.85		24.83	12.41	2.06	
	67 (19.4)	24.89	16.41	1.65	23.83	15.99	1.84	22.71	15.56	2.05	23.83	15.99	1.84
	63 (17.2)††	23.39	15.58	1.84	22.38	15.55	1.84	21.29	15.11	2.05	23.39	15.58	1.84
	62 (16.7)	23.01	15.56	1.84	22.03	15.14	1.84	20.99	14.67	2.05	23.01	15.56	1.84
	57 (13.9)	22.46	22.46	1.84	21.66	21.66	1.83	20.79	20.79	2.05	22.46	22.46	1.84
800	72 (22.2)	27.52	13.92	1.89	26.15	13.46	1.88	24.91	13.04	2.10	27.52	13.92	1.89
	67 (19.4)	25.25	17.44	1.88	24.16	17.03	1.88	23.00	16.60	2.09	25.25	17.44	1.88
	63 (17.2)††	23.76	16.95	1.88	22.72	16.53	1.87	21.80	16.08	2.09	23.76	16.95	1.88
	62 (16.7)	23.47	20.89	1.88	22.49	20.52	1.87	21.52	21.52	2.09	23.47	20.89	1.88
	57 (13.9)	23.30	23.30	1.88	22.44	22.44	1.87	21.33	21.33	2.09	23.30	23.30	1.88

The air entering the condenser (the outdoor unit) is the outside dry bulb design temperature

Remember for Denver the outdoor design temperature is 90° dry bulb. Per Manual S we can be with in 5°. We will use the 95° value.

At first glance this equipment has a SHR of 16,080 / 21,600 = .74
 Now look at the footnote ‡

†† At TVA rating indoor condition (75°F edb/63°F ewb). All other indoor air temperatures are at 80°F edb.



Equipment Selection Cooling

Per Manual S one half of the excess latent capacity can be converted to sensible capacity as this is self-correcting.

Solve for today's example:

Total capacity of 21,600 – Sensible capacity of 16,080 = 5,520 Latent capacity

5,520/2 = 2,760 16,080 + 2,760 = 18,840 new sensible capacity

New SHR 18,840 / 21,600 = .87

Per Manual S we can be up to 15% oversized:

Target total load of 15,832 x 1.15 = 18,206 Btuh < 21,600 Btuh

So we are technically slightly oversized.....

In reality as long as we are within 6,000 Btuh we are in good shape



Equipment Selection Cooling

•What about the effects of altitude?

- If you are moving 1000 cfm at sea level are you moving 1000 cfm at 5000'?
- Air at altitude is less dense
- So you need to move more air at altitude to get the same performance or derate the capacity



Equipment Selection **Cooling**

- All of the performance data provided by the manufacturers is performance at sea level.
- Adjustments must be made for performance at altitude.
- Unfortunately very few if any manufactures provide any guidance for altitude adjustment for air conditioners.
- Fortunately Manual S does in appendix 6



© 2024 Shums Coda Associates

101

101

Equipment Selection **Cooling**

The formula for air density correction:

- $CFM \text{ at Altitude} = \text{Sea-Level Flow Rate} / \text{Density Ratio}$

- The air density correction factor for 5000' is .832

Solve for example house:

- $800 / .832 = 962 \text{ cfm}$



© 2024 Shums Coda Associates

102

102

Equipment Selection **Cooling**

Remember this?

Sensible Heat Equation to calculate a preliminary cooling CFM
 $CFM = 15,832 / (1.1 \times .832 \times 17) = 1,017 \text{ cfm}$

This gave us an approximate CFM for cooling. So a fan speed anywhere from 962 cfm to 1,017 cfm will work for the AC speed.



© 2024 Shums Coda Associates

103

103

Equipment Selection **Cooling**

Now we have determined that our cooling equipment will have the capacity needed at 962 to 1,017 cfm. The question now is will the blower deliver?

AIR DELIVERY—CFM (With Filter)[®]

UNIT SIZE	RETURN-AIR SUPPLY	SPEED	EXTERNAL STATIC PRESSURE (in. wc)							
			0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8
040-08	1 side or bottom	High	1075	1040	995	945	895	840	790	670
		Med-Low	850	825	780	740	685	635	580	480
		Low	740	700	650	620	565	515	455	385
040-12	1 side or bottom	High	1470	1415	1400	1285	1215	1120	995	890
		Med-High	1315	1280	1235	1180	1115	1035	930	825
		Med-Low	1125	1110	1065	1045	990	915	830	740
040-16	1 side or bottom	High	1100	1065	1005	945	900	805	730	610
		Med-High	910	895	840	795	750	655	580	480
		Med-Low	800	785	730	690	645	550	475	385

Remember earlier we used .7 IWC for heat cfm. It appears if we set the blower at High it will deliver 995 cfm. Works for me!



© 2024 Shums Coda Associates

104

104

Equipment Selection **Cooling**

Questions on cooling equipment selection ?

Cooling Equipment Summary

Make	Carrier	
Trade	BASE 13 PURON AC	
Cond	24ABB324(A,W)31	
Coil	CAP**2414A**++TDR	
AHRI ref no.	3250356	
Efficiency	11.0 EER, 13 SEER	
Sensible cooling	18835	Btuh
Latent cooling	2765	Btuh
Total cooling	21600	Btuh
Actual air flow	995	cfm
Air flow factor	0.067	cfm/Btuh
Static pressure	0.70	in H ₂ O
Load sensible heat ratio	1.00	



© 2024 Shums Coda Associates

105

105

Manual D **Duct Sizing**

Now that we have determined the house loads and selected the proper sized equipment, how do we make certain the needed cfm is delivered to each room?

Manual D provides us with design parameters and calculations that will result in a duct system that will provide adequate air flows to rooms. Not designing your ductwork at this stage can have disastrous results like:

- Undersized ductwork effects furnace temperature rise (to high)
- Undersized ductwork effects cooling capacity (freezing coil)
- Equipment efficiency is lessened – more energy is used and comfort levels go down
- Unacceptable noise levels



© 2024 Shums Coda Associates

106

106


Manual D **Duct Sizing**

Manual D requires that the duct system be equipped with balancing dampers.

Manual D will get you close but is not perfect. Some duct over sizing will occur with balancing dampers the flow can be adjusted.

How many contractors actually use balancing dampers on their systems??

In my experience very few, this is not a bad thing but the builder may have some comfort issues.



© 2024 Shums Coda Associates

107

107

Manual D **Duct Sizing**

Steps in duct design:

- Determine cfm flow to each room
- Make a rough sketch of duct runs- supplies and returns. I encourage designers to do this on the framing plan to avoid structural members.
- Collect information on blower and all air side pressure drops. This would be the coil, air filters, registers and grills.



© 2024 Shums Coda Associates

108

108

Manual D Duct Sizing

- Determine the total equivalent length of the duct work. This is the longest supply path plus the longest return path. Don't forget the fittings.
- Determine the friction rate. You will need to know available static pressure.
- Size all ductwork based on needed flow and friction rate.

See how easy it is!!!!



© 2024 Shums Coda Associates

109

109

Manual D Duct Sizing

A reasonably well designed system will be within these parameters:

- Total system flow will be ± 5% of design flow.
- Room flows will be ± 10% of design flow. (I have allowed ± 20%)
- Total system static will be ± 0.10 IWC of design.
- Duct velocities are within Manual D recommendations.



© 2024 Shums Coda Associates

110

110

Manual D Duct Sizing

	Recommended Velocities (FPM)							
	Supply Side				Return Side			
	Recommended		Maximum		Recommended		Maximum	
	Rigid	Flex	Rigid	Flex	Rigid	Flex	Rigid	Flex
Trunk Ducts	700	600	900	700	600	600	700	700
Branch Ducts	600	600	900	700	400	400	700	700
Supply Outlet Face Velocity	Size for throw		700		-----		-----	
Return Grille Face Velocity	-----		-----		-----		500	
Filter Grille Face Velocity	-----		-----		-----		300	

Copy of Table 3-1 from ACCA Manual D



© 2024 Shums Coda Associates

111

111

Manual D Duct Sizing




© 2024 Shums Coda Associates

112

112

Manual D Duct Sizing

The required cfm to each room is relative to the rooms calculated load. Essentially if the room requires 5% of the equipments capacity the room will need 5% of the blower cfm.



© 2024 Shums Coda Associates

113

113

Manual D Duct Sizing

To determine the required cfm per room you must calculate the heating and cooling factors. (Wrightsoft labels this as 'Air Flow Factor')

$$\text{Heating Factor} = \text{Blower Cfm} / \text{MJ8 Heat Loss (for structure)}$$

$$\text{Cooling Factor} = \text{Blower Cfm} / \text{MJ8 Sensible Load (for structure)}$$

Solve for today's house

$$\text{Heating Factor} = 830 / 26,853 = .031$$

$$\text{Cooling Factor} = 995 / 14,954 = .067$$



© 2024 Shums Coda Associates

114

114

Heating Summary		Sensible Cooling Equipment Load Sizing	
Structure	26853 Btu/h	Structure	14654 Btu/h
Loads	0 Btu/h	Loads	0 Btu/h
Control vent (54 cfm)	4212 Btu/h	Control vent (54 cfm)	877 Btu/h
Humidification	0 Btu/h	Blower	0 Btu/h
Piping	0 Btu/h	Use manufacturer's data	0 Btu/h
Equipment load	5136 Btu/h	Rate/multiplier	1.00
		Equipment sensible load	15032 Btu/h
Infiltration		Latent Cooling Equipment Load Sizing	
Method	Simplified	Structure	274 Btu/h
Construction quality	Average	Doors	0 Btu/h
Fireplaces	0	Control vent (54 cfm)	-1291 Btu/h
Area (ft ²)	3022	Equipment latent load	0 Btu/h
Volume (ft ³)	14424	Equipment total load	15032 Btu/h
Air change/hour	0.28	Req. total capacity at 0.85 SHR	1.6 ton
Equip. A/F (cfm)	87		
Heating Equipment Summary		Cooling Equipment Summary	
Make	Carrier	Make	Carrier
Trade	Carrier	Trade	BASE 13 PURCH AC
Model	59M28463-12	Coil	3448012NA-W11
AHRJ ref no.	144276	Coil	CA3P2124A-W-TDR
		AHRJ ref no.	320256
Efficiency	92.1 AFUE	Efficiency	11.0 SEER, 13 SEER
Heating input	40000 Btu/h	Sensible cooling	10035 Btu/h
Heating output	33156 Btu/h	Latent cooling	2765 Btu/h
Temperature rise	48.7F	Total cooling	12800 Btu/h
Actual air flow	230 cfm	Actual air flow	395 cfm
Air flow factor	0.031 cfm/Btu	Air flow factor	0.067 cfm/Btu
Space thermostat	69F setpoint	Load sensible heat ratio	1.00



© 2024 Shums Coda Associates

115

115

Manual D Duct Sizing

The Wrightsoft program does most of the work for you. The proper inputs are critical.

Determine your available static pressure:

- Start with the static pressure you used for the equipment. Remember we used .7 IWC.
- Enter the AC coil resistance. This found in the manufactures performance data.
- Enter heat exchanger resistance. Ours was included with the performance data.

- Enter supply registers and return grille resistance. We will use .03 IWC.
- Enter filter resistance. Most performance data includes 'cost effective' filter.
- Enter humidifier resistance, from manufactures performance data.
- Enter balancing dampers if used.
- Any other devices like air cleaners etc.



© 2024 Shums Coda Associates

116

116

Manual D Duct Sizing

Static Pressure for Entire House			
External static pressure			
Pressure losses			
Coil	0.25	0.25	
Heat exchanger	0	0	
Supply diffusers	0.03	0.03	
Return grilles	0.03	0.03	
Filter	0.10	0.10	
Humidifier	0	0	
Balancing damper	0	0	
Other device	0	0	
Available static pressure	0.29	0.29	
Measured length of run-out			
Measured length of trunk			
Equivalent length of fittings			
Total length	190	115	
Total effective length		305	
Friction Rate			
Heating (in/100ft)	[0.095]	OK	
Cooling (in/100ft)	[0.095]	OK	
Supply	[0.095]	OK	
Return	[0.095]	OK	



© 2024 Shums Coda Associates

117

117

Manual D Duct Sizing

This is the friction rate formula: $ASP \times 100 / TEL$

Where:

- ASP = Available static pressure
- 100 = The friction rate is per 100' of duct length
- TEL = Total Equivalent Length of ductwork

Solve:

$$.29 \times 100 / 305 = .095$$

Per Manual D the friction rate must be not less than 0.06 and not more than 0.18.



© 2024 Shums Coda Associates

118

118

Manual D Duct Sizing

Project Information		
For: Colorado ED Inst. March 2012		
External static pressure	Heating	Cooling
Pressure losses	0.70 in H2O	0.70 in H2O
Available static pressure	0.41 in H2O	0.41 in H2O
Supply / return available pressure	0.29 in H2O	0.29 in H2O
Lowest friction rate	0.18 / 0.11 in H2O	0.18 / 0.11 in H2O
Actual air flow	0.095 in/100ft	0.095 in/100ft
Total effective length (TEL)	830 cfm	305 ft
		995 cfm



© 2024 Shums Coda Associates

119

119

Manual D Duct Sizing

Duct preferences for today's house

Fitting Preferences			
Metal	Elbows	Rect supp	BB3 ***
	Round supp	BAE ***	
	Rect ret	BB3 ***	
	Round ret	BAE ***	
Flex		111 ***	
Supply	Takeoffs	Rect	ZH1 ***
		Round	ZJ0 ***
	Return	Rect	FB1 ***
		Round	FC3 ***



© 2024 Shums Coda Associates

120

120

Manual D Duct Sizing

Duct preferences for today's house

Category	Material	Fitting ID	Icon		
Supply	trunk	Rnd br	9A1	...	[Icon]
	Round trunk		9I1	...	[Icon]
	Rect branch		10A	...	[Icon]
	Round branch		10G	...	[Icon]
Return	Rect		1P	...	[Icon]
	Round		1A	...	[Icon]
Fan Fittings	Supply	Rect	1P	...	[Icon]
	Supply	Round	1A	...	[Icon]
	Return	Rect	5K	...	[Icon]
	Return	Round	5D	...	[Icon]



© 2024 Shums Coda Associates

121

121

Manual D Duct Sizing

Fitting Preferences

Material	Category	Fitting ID	Icon		
Metal	Elbows	Rect supp	8B3	...	[Icon]
		Round supp	8AE	...	[Icon]
	Takeoffs	Rect	2H1	...	[Icon]
		Round	2J0	...	[Icon]
Flex	Rect	8B3	...	[Icon]	
	Round	8AE	...	[Icon]	
Flex	Supply	Rect	6B1	...	[Icon]
	Return	Round	6C3	...	[Icon]

•Note: Round Supply 8AE



© 2024 Shums Coda Associates

122

122

Manual D Duct Sizing

Equivalent lengths for elbows and offsets.

Picture	ID	Eq.Len.	Fitting Description
[Icon]	SA6	20	Smooth elbow, RD = 0.75
[Icon]	SA9	15	Smooth elbow, RD = 1.0
[Icon]	SAE	10	Smooth elbow, RD = 1.5
[Icon]	SA7	30	4 or 5 piece elbow, RD = 0.75
[Icon]	SA4	20	4 or 5 piece elbow, RD = 1.0
[Icon]	SAF	15	4 or 5 piece elbow, RD = 1.5
[Icon]	SAB	35	3 piece elbow, RD = 0.75
[Icon]	SAB	25	3 piece elbow, RD = 1.0
[Icon]	SAX	20	3 piece elbow, RD = 1.5
[Icon]	SA1	75	Smooth mitered elbow



© 2024 Shums Coda Associates

123

123

Manual D Duct Sizing

Category	Material	Fitting ID	Icon		
Boots	Supply	4AD	...	[Icon]	
	Return	4M	...	[Icon]	
Flex Junctions	3 ducts	11M	...	[Icon]	
	> 3 ducts	11A	...	[Icon]	
Transitions	Supply	Rect	12C1	...	[Icon]
		Round	12A1	...	[Icon]
	Return	Rect	12F1	...	[Icon]
		Round	12D1	...	[Icon]
Fan Fittings	Supply	Rect	1P	...	[Icon]
		Round	1A	...	[Icon]
	Return	Rect	5K	...	[Icon]
		Round	5D	...	[Icon]

•Note: Supply Fan Fitting 1P



© 2024 Shums Coda Associates

124

124

Manual D Duct Sizing

Group 1. Supply Air Fitting at the Air Handling Equipment

Picture	ID	Eq.Len.	Fitting Description
	1N	15	90 deg. rect. elbow with transition
	1O1	120	Rect. tee, no vanes, HW = 0.5
	1O2	85	Rect. tee, no vanes, HW = 1.0
	1P	20	Rect. tee with vanes
	1Q	120	90 deg. rect. elbow - 10" min. from unit, no vanes
	1R	50	90 deg. rect. elbow - 10" min. from unit, with vanes
	1S1	60	90 deg. rect. radius elbow - 10" min from unit, no vanes

Sup at AH Sup take-offs Reducing take-offs Sup boots/stacks Ret at AH Ret BR fittings

© 2024 Shums Coda Associates

125

125

Manual D Duct Sizing

Boots

Supply	
Return	

Flex Junctions

3 ducts	
> 3 ducts	

Transitions

Supply	Rect	
	Round	
Return	Rect	
	Round	

Trunk Junction Fittings

Supply	Rect trunk	Rect br	
		Rnd br	
Return	Round trunk		
	Rect branch		
	Round branch		

Fan Fittings

Supply	Rect	
	Round	
Return	Rect	
	Round	

© 2024 Shums Coda Associates

126

126

• Note: Supply Fan Fitting 5K

126

Manual D Duct Sizing

Group 5. Return Air Fittings at the Air Handling Equipment

Picture	ID	Eq.Len.	Fitting Description
	S1	45	Mitered inside corner elbow, HW = 1.0
	S2	30	Mitered inside corner elbow, HW = 2.0
	SJ1	20	Radius elbow, RW = 0.25
	SJ2	15	Radius elbow, RW = 0.50
	SJ3	10	Radius elbow, RW = 1.00
	5K	10	Square elbow with vanes
	5L	75	Rect. tee, no vanes
	5M	10	Rect. tee with vanes

Sup boots/stacks Ret at AH Ret BR fittings Ret joists/studs Elbows/offsets Sup TR ju

© 2024 Shums Coda Associates

127

127

127

Manual D Duct Sizing

Fitting Preferences

Elbows

Metal	Rect supp	
	Round supp	
	Rect ret	
	Round ret	
Flex		

Takeoffs

Supply	Rect	
	Round	
Return	Rect	
	Round	

© 2024 Shums Coda Associates

128

128

• Note: Round Supply 2J0

128

Manual D Duct Sizing

Picture	ID	Eq.Len.	Fitting Description
	2H4	65	Rect. from side with scoop, 4 distr br
	2H5	95	Rect. from side with scoop, 5 or more br
	2I0	65	Round from top, no transition, 0 distr br
	2I1	75	Round from top, no transition, 1 distr br
	2I2	85	Round from top, no transition, 2 distr br
	2I3	95	Round from top, no transition, 3 distr br
	2I4	100	Round from top, no transition, 4 distr br
	2I5	110	Round from top, no transition, 5 or more br
	2J0	50	Round from top with round transition, 0 distr br
	2J1	60	Round from top with round transition, 1 distr br
	2J2	65	Round from top with round transition, 2 distr br
	2J3	70	Round from top with round transition, 3 distr br
	2J4	75	Round from top with round transition, 4 distr br
	2J5	80	Round from top with round transition, 5 or more br
	2K0	50	Round from top with rect. transition, 0 distr br
	2K1	60	Round from top with rect. transition, 1 distr br
	2K2	65	Round from top with rect. transition, 2 distr br


© 2024 Shums Coda Associates

129

129

Manual D Duct Sizing

Today's House




© 2024 Shums Coda Associates

130

130

Manual D Duct Sizing




© 2024 Shums Coda Associates

131

131


Manual D Duct Sizing



© 2024 Shums Coda Associates

132

132



133

R404.2 Interior lighting controls

Permanently installed lighting fixtures shall be controlled with either a dimmer, an occupant sensor control or other control that is installed or built into the fixture.


Exception: Lighting controls shall not be required for the following:

1. Bathrooms.
2. Hallways.
3. Exterior lighting fixtures.
4. Lighting designed for safety or security.


ALL PERMANENTLY INSTALLED LIGHTING FIXTURES SHALL CONTAIN ONLY HIGH-EFFICIENCY LIGHTING SOURCES. N1104.1.1
 PERMANENTLY INSTALLED INTERIOR LIGHTING FIXTURES SHALL COMPLY WITH IRC N1104.2
 EXTERIOR LIGHTING FIXTURES THAT HAVE 30 WATTS OR MORE OF POWER SHALL BE INSTALLED WITH AUTOMATIC SHUT OFF DURING DAYLIGHT HOURS PER N1104.3

© 2024 Shums Coda Associates 134

134



135



136

R404.3 Exterior lighting controls

ALL PERMANENTLY INSTALLED LIGHTING FIXTURES SHALL CONTAIN ONLY HIGH-EFFICIENCY LIGHTING SOURCES. N1104.1.1
 PERMANENTLY INSTALLED INTERIOR LIGHTING FIXTURES SHALL COMPLY WITH IRC N1104.2
 EXTERIOR LIGHTING FIXTURES THAT HAVE 30 WATTS OR MORE OF POWER SHALL BE INSTALLED WITH AUTOMATIC SHUT OFF DURING DAYLIGHT HOURS PER N1104.3

Where the total permanently installed exterior lighting power is greater than 30 watts, the permanently installed exterior lighting shall comply with the following:

1. Lighting shall be controlled by a manual on and off switch which permits automatic shut-off actions.

Exception: Lighting serving multiple dwelling units.

2. Lighting shall be automatically shut off when daylight is present and satisfies the lighting needs.

3. Controls that override automatic shut-off actions shall not be allowed unless the override automatically returns automatic control to its normal operation within 24 hour




© 2024 Shums Coda Associates

137

137

R404.3



138

138

R408 Additional Efficiency Package Options

R408.2.1 Enhanced envelope performance option

The total building thermal envelope UA, the sum of U-factor times assembly area, shall be less than or equal to 95 percent of the total UA resulting from multiplying the U-factors in Table R402.1.2 by the same assembly area as in the proposed building.

The UA calculation shall be performed in accordance with Section R402.1.5. The area-weighted average SHGC of all glazed fenestration shall be less than or equal to 95 percent of the maximum glazed fenestration SHGC in Table R402.1.2.



© 2024 Shums Coda Associates

139

139

R408 Additional Efficiency Package Options

R408.2.2 More efficient HVAC equipment performance option

Heating and cooling equipment shall meet one of the following efficiencies:

1. Greater than or equal to 95 AFUE natural gas furnace and 16 SEER air conditioner.
 2. Greater than or equal to 10 HSPF/16 SEER air source heat pump.
 3. Greater than or equal to 3.5 COP ground source heat pump.
- For multiple cooling systems, all systems shall meet or exceed the minimum efficiency requirements in this section and shall be sized to serve 100 percent of the cooling design load. For multiple heating systems, all systems shall meet or exceed the minimum efficiency requirements in this section and shall be sized to serve 100 percent of the heating design load.

Additional Efficiency Package Option - HVAC Equipment Performance:
 Provide greater than or equal to 95 AFUE natural gas furnace and 21 SEER air conditioner.



Variable-speed | Modulating
 Communicating | Up to 97.3% AFUE



© 2024 Shums Coda Associates

140


140

R408 Additional Efficiency Package Options

R408.2.3 Reduced energy use in service water-heating option

The hot water system shall meet one of the following efficiencies:

1. Greater than or equal to 0.82 EF fossil fuel service water-heating system.
2. Greater than or equal to 2.0 EF electric service water-heating system.
3. Greater than or equal to 0.4 solar fraction solar water-heating system.



© 2024 Shums Coda Associates

141

141

R408 Additional Efficiency Package Options

R408.2.4 More efficient duct thermal distribution system option

The thermal distribution system shall meet one of the following efficiencies:

1. 100 percent of ducts and air handlers located entirely within the building thermal envelope.
2. 100 percent of ductless thermal distribution system or hydronic thermal distribution system located completely inside the building thermal envelope.
3. 100 percent of duct thermal distribution system located in conditioned space as defined by Section R403.3.2.



© 2024 Shums Coda Associates

142

142

R408 Additional Efficiency Package Options

R408.2.5 Improved air sealing and efficient ventilation system option

The measured air leakage rate shall be less than or equal to 3.0 ACH50, with either an Energy Recovery Ventilator (ERV) or Heat Recovery Ventilator (HRV) installed. Minimum HRV and ERV requirements, measured at the lowest tested net supply airflow, shall be greater than or equal to 75 percent Sensible Recovery Efficiency (SRE), less than or equal to 1.1 cubic feet per minute per watt and shall not use recirculation as a defrost strategy. In addition, the ERV shall be greater than or equal to 50 percent Latent Recovery/Moisture Transfer (LRMT).



© 2024 Shums Coda Associates

143

143

Copyright Materials

This presentation is protected by US and International Copyright laws. Reproduction, distribution, display and use of the presentation without written permission of the speaker is prohibited.

© Shums Coda Associates, Inc.



© 2024 Shums Coda Associates

144

144



SHUMS CODA
ASSOCIATES

- 4610 S Ulster, Suite 150
- Denver, CO 80237

- Ph. 303-400-6564
- Fax 303-693-0630

- www.shumscoda.com
- gil.rossmiller@shumscoda.com



© 2024 Shums Coda Associates



145

145